

## RFQ Questions and Responses 19-20-01 Electrical Engineer

### Building 700 Transformer Replacement

**Question:** What is the reason for the replacement of the transformers? Age? Capacity?

**Response:** Primarily Age but future capacity may be a consideration

**Question:** Is it expected to replace the transformers with a transformer of same capacity?

**Response:** This is to be determined by a qualified Electrical Engineer

**Question:** Is the plan to reuse existing primary and secondary feeders?

**Response:** These were replaced 2 years ago so unlikely but this is to be determined by a qualified Electrical Engineer

**Question:** What is the kVA capacity, primary and secondary voltage of the transformer are being replaced?

**Response:** See photos attached

**Question:** Is there a requirement to plan for temporary power while the transformers are being replaced?

**Response:** Yes

**Question:** Are there as-built drawings that can be shared?

**Response:** We have an as-built titled "High Voltage Feeder Replacement" dated 9-25-17 and the original building plans from 1961

**Question:** Please confirm the replacement is for additional electrical service capacity or for equipment damage or for service ability.

**Response:** Primarily Age but future capacity may be a consideration

**Question:** Will the high voltage supply circuits to these transformers require modifications or upgrades?

**Response:** These were replaced 2 years ago so unlikely but this is to be determined by a qualified Electrical Engineer

**Question:** Will the service conduit/conductors to the building require modification upgrades?

**Response:** This is to be determined by a qualified Electrical Engineer

**Question:** Will the service/distribution equipment fed from these transformers require modification or repair

**Response:** This is to be determined by a qualified Electrical Engineer

**Question:** Do campus or district standards require dry type or liquid-filled: completely self-protected or primary load interrupter switch equipment's.

**Response:** no district standard is currently in place This is to be determined by a qualified Electrical Engineer

**Question:** Are the transformers located indoors or outdoors in an equipment yard?

**Response:** outdoors in a fully accessible vented enclosure

## RFQ Questions and Responses 19-20-01 Electrical Engineer

### Exterior Lighting Upgrades

**Question:** Do the exterior lighting upgrades for the track include sports lighting? If so, provide athletic division and any spectator requirements.

**Response:** yes, the extent shall be determined by design professionals in the programming phase of the project

**Question:** Is there an intent for the lighting upgrade to include the center of the track for the field events?

**Response:** This shall be determined by design professionals in the programming phase of the project

**Question:** Is there existing campus lighting standard (fixtures, controls).

**Response:** There is no current district standard

**Question:** Are there existing perimeter lighting that will need to be replaced or will all this be new design?

**Response:** New design

**Question:** Are there any site lighting as-built drawings that can be shared?

**Response:** The original 1961 plans will be provided

**Question:** Will you be providing drawings and /or sq. ft. for the exterior lighting project?

**Response:** This shall be determined by design professionals in the programming phase of the project

**Question:** Please confirm if “track” also requires “athletic field” lighting and/or controls.

**Response:** Yes, and the extent shall be determined by design professionals in the programming phase of the project

**Question:** Does the campus or district have specific lighting performance or aesthetic standards?

**Response:** This shall be determined by design professionals in the programming phase of the project

**Question:** Please confirm that compliance to California Title 24 shall be a requirement?

**Response:** This shall be determined by design professionals in the programming phase of the project

**PHOTOS OF EXISTING TRANSFORMER IDENTIFICATION PLATES ATTACHED BELOW**



# NIAGARA TRANSFORMER CORP.

BUFFALO, NEW YORK, U.S.A.

KVA 225 60 CYCLE SERIAL NO. 33119

H.V. 11600 CORE & COILS 1250 LBS.

L.V. 2880/1200 °C. RISE 35 TANK & FITTINGS 1100 LBS.

H.V. BIL 30KV L.V. BIL 30KV UNTANKING 1250 LBS.


3 PHASE CLASS 20 LIQUID 500 LBS.

%IMP 3.5 AT 85 APPROX. TOTAL WT. 2850 LBS.

INSTRUCTION BOOK NO. 5512 TRANSFORMER FILLED WITH 29 GALS. 1500

H.V. CONNECTION			
VOLTS	AMPS	TC ON	CONNECTS
12600	2074	A	4-5
12600	2074	B	3-5
2160	2123	C	3-6
1056	3203	D	2-6
2052	3287	E	2-7

**CAUTION: DO NOT CHANGE TAPS WITH TRANSFORMER ENERGIZED**



FORM 9-1-30

33003

# Sierra



**Transformer Company**  
LOS ANGELES, CALIF.

**KVA PH. VOLTAGE RATING % IMP. GAL. OIL**

500 3 4160 = 480V/277 4.5 175

**POLARITY WEIGHT SERIAL CAT. NO.**

D-Y 4686 13478-1 50 712

**60 CYCLES 65C RISE CLASS O A TRANSFORMER**  
**BEFORE INSTALLING READ INSTALLATION INSTRUCTIONS D-130**

%RATED VOLTS	TAP POSITION
105	1
102.5	2
100	3
97.5	4
95	5

